



Dear Sir / Madam,

24th September 2024

TENDER ADDENDUM NO. 1

TENDER NO: ONT/KDC/001/24-25

**TENDER NAME: SUPPLY, INSTALLATION, TESTING AND COMMISSIONING
OF LIFTS AT FINANCE HOUSE**

In reference to the above-mentioned tender, the following clarifications are made to the specified provisions of the Tender Document:

INQUIRY:

We request clarification on the subject tender document as follows;

On the Bills of Quantities Bill No. 2 item number 1.15 (Page 88 of Document), the specification states, "All the **Landing and car doors** on all floors and stops for the 4 No lifts to be **Gold coated or colored** to approval" whereas on schedule 6.0 Technical Specification for lifts (Page 112 of document) , the specification for Landing and car door reads, " **Landing door** : Stainless steel to Engineer's approval with mirror finish. **Car door**: Stainless steel to Engineer's approval."

Kindly clarify on this.

RESPONSE:

All landing doors and car doors for all the 4 No. lifts should be made of stainless steel to Engineer's approval and in addition to that, the doors should be gold coated and or color coated to approval.

The description in the Bills of Quantities Bill number 2 Price schedule 1 item 1.15 qualifies the specifications on matters color finish of all the doors as well as car interior finishes for all the lifts.

Tenderers are advised to consider the finishes types as described in BQs when pricing. The Employer/employer's representative will bear neither responsibility nor liability for the tenderers failure to consider these finishes in their pricing

All other terms and conditions of the tender remain unchanged.

Yours faithfully,

For: **KENYA DEVELOPMENT CORPORATION LTD**

JOSEPH WAKA

FOR: DIRECTOR GENERAL